

Karl Wolpers Postfach 10 1444 31114 Hildesheim

König Glasbau GmbH & Co. KG
z. H. Herrn Bäsecke
Dieselstraße 4

38350 Helmstedt

Kitte
Dichtstoffe
Schaumstoffe
Verarbeitungswerkzeuge

Gips
Mineralfutter
Sportplatzkreide
Wirkstoff-Vormischungen

18. März 2003

Contact/tel. ext.
Herr Mössinger/Fi/-35

Date:
17.03.2003

Adhesion of KAWO silicone to Signapur glass coating

Dear Herr Bäsecke,

As requested, we have investigated the panes of glass handed over to us, coated with the above-mentioned sealing material from Messrs. Purratio, and wish to inform you of the results as follows:

Our silicone glass sealants KAWO SL 52, KAWO SL 54 and KAWO SL 55 were tested without primer and without prior cleaning.

To summarise, we are able to state that we were unable to establish any impairment whatsoever of the adhesion to the glass on the surface coated with Signapur. Therefore it is compatible with our sealants with no restrictions.

Yours sincerely,

Karl Wolpers

(signature)

The above information and our advice on applications verbally, in print and from trials are given to the best of our knowledge but only constitute non-binding information, also with reference to any rights of third parties. The advice does not release you from the obligation to undertake your own tests with reference to our advice and our products with regard to their suitability for the intended processes and purposes. The use and processing of our products and the products manufactured by you on the basis of our advice on applications technology, take place in circumstances beyond our control and are therefore exclusively within your sphere of responsibility.